

Application Acknowledgement



West Bengal
eDISTRICT 2.0

Single Window Portal - Citizen Centric Services & Schemes

Dear Mr. Susanta Paul,

Thank you for using West Bengal e-District 2.0 System.

Your application for Renewal of Fire Safety Certificate under Government of West Bengal has been successfully submitted.

Application Summary

AIN : 211912606300012409

Name of the Applicant : Mr. Susanta Paul

Date of the Application : 17-Jul-2026

Address : AISHTALA, GARER BAGAN, P.O. AND P.S.- RANAGHAT, UNDER RAMNAGAR - I GRAM PANCHAYAT, JL NO.-114, L.R. PLOT NO.-1911,1915,1922, RS PLOT NO.-724,725,727, RS KHATIAN NO.-535, 679, 688, LR KHATIAN NO.- 1323/1, 3151,3152,3663, RS DAG NO.-723, 724,725 AND 727, LR DAG NO.- 1911,1915,1922

For any query please contact your nearest Kiosk operator or the following contact details:

Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D,
Mirza Ghalib Street, Kolkata – 16


Principal
St. Mary's Arcadian School
Aishtala, Ranaghat, Nadia


Manager
St. Mary's Arcadian School
Aishtala, Ranaghat, Nadia



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20182019/22218

Date: 01-06-2023

From:

Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: ST MARYS ARCADIAN SCHOOL

AISHTALA, RANAGHAT, DIST-NADIA , PIN CODE-741201.

Sub: Renewal of Fire Safety Certificate for existing construction of G+III storied building under group of Educational Building in the name & style of "ST. MARYS ARCADIAN SCHOOL" at the premises no. Aishtala, Garer Bagan, P.O. + P.S. Ranaghat, Dist. Nadia, under Ramnagar I Gram Panchayet, Mouza Aishtala, J.L. no. 114, L.R. Plot no. 1911, 1915, 1922, R.S. Plot no. 724, 725, 727, R.S. Khatian no. 535, 679, 688, L.R. Khatian no. 1323/1, 3151, 3152, 3663, R.S. Dag no. 723, 724, 725 and 727, LRS Dag no. 1911, 1915, 1922 & 1923, PIN 741201.

This is in reference to your application no. 0125191231000048 dated 02-05-2023 regarding the Renewal of Fire Safety Certificate for existing construction of G+III storied building under group of Educational Building in the name & style of "ST. MARYS ARCADIAN SCHOOL" at the premises no. Aishtala, Garer Bagan, P.O. + P.S. Ranaghat, Dist. Nadia, under Ramnagar I Gram Panchayet, Mouza Aishtala, J.L. no. 114, L.R. Plot no. 1911, 1915, 1922, R.S. Plot no. 724, 725, 727, R.S. Khatian no. 535, 679, 688, L.R. Khatian no. 1323/1, 3151, 3152, 3663, R.S. Dag no. 723, 724, 725 and 727, LRS Dag no. 1911, 1915, 1922 & 1923, PIN 741201.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

CONDITION : AUTOMATIC SPRINKLER & DETECTION SYSTEM TO BE INSTALLED IN THE SEMINAR HALL AND AUDITORIUM.

1 The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.

